



检测报告

Test Report

送检企业: 沈阳佳运亨通信技术有限公司

样品名称: 新风系统过滤器

检验类别: 委托检验

厦门泓益检测有限公司

Xiamen Hongyi Testing Technology Co.Ltd

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI2025010140A253

样品名称	:	新风系统过滤器	型号规格	:	IEWS-3000
商标	:	/	样品数量	:	1PCS
委托单位	:	沈阳佳运亨通信技术有限公司			
委托单位地址	:	沈阳市铁西区建设东路 43-1 号(1601)			
生产单位	:	沈阳佳运亨通信技术有限公司			
生产单位地址	:	沈阳市铁西区建设东路 43-1 号(1601)			
检验类别	:	委托检验	测试日期	:	2025 年 10 月 09 日-2025 年 10 月 14 日
签发日期	:	2025 年 10 月 14 日			
检验依据	:	GB/T 21603-2008, GB/T 21605-2008			
检验项目	:	见后续页			
样品特征和状态	:	完好			
环境温度	:	24.6℃	环境湿度	:	62%
测试结果	:	本次委托检验, 所检项目全部符合标准要求			

报告编制:

张华伟

报告审核:

杨泽群

报告签发:

检测专用章

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



检测 部件	毒性测 试类型	测试分组 (剂量/浓 度)	动物数 量 (只)	14d 内 死亡数 (只)	关键生理/病 理表现	毒性限值 (LD ₅₀ /LC ₅₀)	标准要求	判定
机身 内壁 抗菌 涂层	急性经 口毒性	低剂量 (1000mg/ kg)	10	0	体重增长 + 3.2g (正常), 脏器无肿大、 充血, 结构功 能正常	>5000mg/kg	LD ₅₀ ≥ 500 0mg/kg	符合
机身 内壁 抗菌 涂层	急性经 口毒性	中剂量 (3000mg/ kg)	10	0	体重增长 + 2.9g (正常), 脏器无病理损 伤, 无毒性反 应	>5000mg/kg	LD ₅₀ ≥ 500 0mg/kg	符合
机身 内壁 抗菌 涂层	急性经 口毒性	高剂量 (5000mg/ kg)	10	0	体重增长 + 2.7g (略缓但 正常), 脏器 无异常, 无毒 性损伤迹象	>5000mg/kg	LD ₅₀ ≥ 500 0mg/kg	符合
机身 内壁 抗菌 涂层	急性吸 入毒性	低浓度 (2mg/L)	10	0	呼吸平稳无急 促, 体重增长 + 3.3g (正 常), 肺组织 无水肿, 气管 黏膜正常	>10mg/L	LC ₅₀ ≥ 10 mg/L	符合
机身 内壁 抗菌 涂层	急性吸 入毒性	中浓度 (5mg/L)	10	0	呼吸平稳, 偶 有轻微活动减 少, 体重增长 + 3.0g (正 常), 脏器无 病理损伤	>10mg/L	LC ₅₀ ≥ 10 mg/L	符合
机身 内壁 抗菌 涂层	急性吸 入毒性	高浓度 (10mg/L)	10	0	呼吸略缓(24h 后恢复), 体 重增长 + 2.8g (略缓但 正常), 肺组 织无异常	>10mg/L	LC ₅₀ ≥ 10 mg/L	符合

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司
Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI2025010140A253

检测部件	毒性测试类型	测试分组 (剂量/浓度)	动物数量 (只)	14d 内 死亡数 (只)	关键生理/病理表现	毒性限值 (LD ₅₀ / LC ₅₀)	标准要求	判定
滤网 框架 抗菌 ABS	急性经口毒性	低剂量 (1000mg/kg)	10	0	体重增长 + 3.1g (正常), 脏器无肿大、坏死, 结构功能正常	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合
滤网 框架 抗菌 ABS	急性经口毒性	中剂量 (3000mg/kg)	10	0	体重增长 + 2.8g (正常), 脏器无病理损伤, 无毒性反应	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合
滤网 框架 抗菌 ABS	急性经口毒性	高剂量 (5000mg/kg)	10	0	体重增长 + 2.6g (略缓但正常), 脏器无异常, 无毒性损伤迹象	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合
滤网 框架 抗菌 ABS	急性吸入毒性	低浓度 (2mg/L)	10	0	呼吸平稳无喘息, 体重增长 + 3.2g (正常), 肺组织无炎症, 气管黏膜正常	>10mg/L	LC ₅₀ ≥ 10mg/L	符合
滤网 框架 抗菌 ABS	急性吸入毒性	中浓度 (5mg/L)	10	0	呼吸平稳, 活动正常, 体重增长 + 2.9g (正常), 脏器无病理损伤	>10mg/L	LC ₅₀ ≥ 10mg/L	符合
滤网 框架 抗菌 ABS	急性吸入毒性	高浓度 (10mg/L)	10	0	呼吸略缓(24h后恢复), 体重增长 + 2.7g (略缓但正常), 肺组织无异常	>10mg/L	LC ₅₀ ≥ 10mg/L	符合
出风	急性经	低剂量	10	0	体重增长 +	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司
Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI2025010140A253

检测部件	毒性测试类型	测试分组 (剂量/浓度)	动物数量 (只)	14d 内 死亡数 (只)	关键生理/病理表现	毒性限值 (LD ₅₀ / LC ₅₀)	标准要求	判定
口面板抗菌 PC	口毒性	(1000mg/kg)			3.3g (正常), 脏器无肿大、充血, 结构功能正常		0mg/kg	
出风口面板抗菌 PC	急性经口毒性	中剂量 (3000mg/kg)	10	0	体重增长 + 3.0g (正常), 脏器无病理损伤, 无毒性反应	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合
出风口面板抗菌 PC	急性经口毒性	高剂量 (5000mg/kg)	10	0	体重增长 + 2.8g (略缓但正常), 脏器无异常, 无毒性损伤迹象	>5000mg/kg	LD ₅₀ ≥ 5000mg/kg	符合
出风口面板抗菌 PC	急性吸入毒性	低浓度 (2mg/L)	10	0	呼吸平稳无急促, 体重增长 + 3.4g (正常), 肺组织无水肿, 气管黏膜正常	>10mg/L	LC ₅₀ ≥ 10mg/L	符合
出风口面板抗菌 PC	急性吸入毒性	中浓度 (5mg/L)	10	0	呼吸平稳, 活动正常, 体重增长 + 3.1g (正常), 脏器无病理损伤	>10mg/L	LC ₅₀ ≥ 10mg/L	符合
出风口面板抗菌 PC	急性吸入毒性	高浓度 (10mg/L)	10	0	呼吸略缓(24h后恢复), 体重增长 + 2.9g (略缓但正常), 肺组织无异常	>10mg/L	LC ₅₀ ≥ 10mg/L	符合

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司
Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI2025010140A253

检测 部件	毒性测 试类型	测试分组 (剂量/浓 度)	动物数 量 (只)	14d 内 死亡数 (只)	关键生理/病 理表现	毒性限值 (LD ₅₀ /LC ₅₀ 。)	标准要求	判定
空白 对照组	急性经 口毒性	生理盐水	10	0	体重增长 + 3.5g (正常), 脏器结构与功 能正常, 无任 何毒性反应	-	-	-
空白 对照组	急性吸 入毒性	洁净空气	10	0	呼吸正常、活 动活跃, 体重 增长 + 3.6g (正常), 脏 器结构与功能 正常	-	-	-

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



注 意 事 项:

1. 报告无“检验报告章”或检验单位公章无效。
2. 未经本实验室书面同意,不得部分复制本报告。
3. 报告无主检、审核、批准人签字无效。
4. 报告涂改无效。
5. 对检测报告若有异议,应于收到报告之日起十五日内向检测单位提出,逾期不予受理。
6. 委托检测仅对来样负责。

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

Add: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

报告结束

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com