



# 检测报告

## Test Report

**Applicant:** Huizhou Zhongcheng Electronic Technology Co., Ltd.

**Sample Name:** Single-phase Smart Meter

**Test Type:** Commissioned Test



厦门泓益检测有限公司

**Xiamen Hongyi Testing Technology Co., Ltd.**

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号


ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com




<b>Sample Name</b>	: Single-phase Smart Meter	<b>Model Specification</b>	: DDSY1398 230V 5(60)A 50Hz
<b>Trademark</b>	: <b>ZCET</b>	<b>Sample Quantity</b>	: 3 pcs
<b>Entrust Unit</b>	: Huizhou Zhongcheng Electronic Technology Co., Ltd.		
<b>Entrust Unit Address</b>	: No.7 Hechang East Fourth Road, Zhongkai High-tech Zone, Huizhou City, Guangdong Province		
<b>Manufacturer</b>	: Huizhou Zhongcheng Electronic Technology Co., Ltd.		
<b>Manufacturer Address</b>	: No.7 Hechang East Fourth Road, Zhongkai High-tech Zone, Huizhou City, Guangdong Province		
<b>Test Type</b>	: Commissioned Test	<b>Test Date</b>	: August 01, 2025 - September 30, 2025
<b>Issuance Date</b>	: September 30, 2025		
<b>Test Basis</b>	: IEC 62053-21:2003 AC Electrical Measuring Equipment - Special Requirements - Part 21: Static Active Energy Meters (Class 1 and 2) IEC 62053-23:2003 AC Electrical Measuring Equipment - Special Requirements - Part 23: Static Reactive Energy Meters (Class 2 and 3) IEC 62052-11:2003 AC Electrical Measuring Equipment - General Requirements, Tests and Test Conditions - Part 11: Measuring Equipment		
<b>Test Items</b>	: Refer to the following section		
<b>Sample Characteristics and Status</b>	: Intact upon receipt		
<b>Ambient Temperature</b>	: 24.6°C	<b>Ambient Humidity</b>	: 62%
<b>Test Results</b>	: The Single-phase Smart Meter complies with the requirements of IEC 62053-21:2003, IEC 62053-23 and IEC 62052-11:2003 standards.		

Report Prepared by:



Report Reviewed by:



Report Approved by:



This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



## Content

1. Test of limits of errors due to variation of the current
2. Test of starting condition
3. Test of no-load conditions
4. Test of meter constant
5. AC voltage tests
6. Impulse voltage test
7. Test of ambient temperature influence
8. Test of influence of self-heating
9. Test of influence of voltage variation
10. Test of influence of frequency variation
11. Test of magnetic induction of external origin (0.5 mT)
12. Test of the influence of harmonics
13. Test of influence of short time over currents
14. Spring hammer test
15. Test of resistance to heat and fire
16. Test of power consumption
17. Test of influence of heating
18. Damp heat cyclic test
19. Vibration test
20. Shock test
21. Dry heat test
22. Cold test
23. Test of immunity to electromagnetic HF fields
24. Fast transient burst test
25. Test of immunity to electrostatic discharges
26. Tests of the effect of voltage dips and short interruptions
27. Test of continuous magnetic induction of external origin
28. Marking and elements test
29. Test of supply voltage operating range
30. Test of initial start-up
31. Surge immunity test
32. Radio interference measurement
33. Test of immunity to conducted disturbances, induced radio-frequency fields
34. Test of solar radiation
35. Test of protection against penetration of water
36. Test of protection against penetration of dust

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

## Test condition:

Ambient temperature: (21 ~ 24)°C    Relative humidity: (40 ~ 60) %

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 1. Test of limits of errors due to variation of the current

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: When the meter is under the reference conditions, the percentage errors shall not exceed the limits.
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	±1.5	-0.1	0.1	-0.1
0.1I <sub>b</sub>	1.0	±1.0	0.0	0.0	0.1
0.5I <sub>b</sub>	1.0	±1.0	-0.1	-0.1	0.0
I <sub>b</sub>	1.0	±1.0	-0.1	0.0	-0.1
0.5I <sub>max</sub>	1.0	±1.0	-0.1	0.0	-0.1
I <sub>max</sub>	1.0	±1.0	-0.2	0.0	-0.1
0.1I <sub>b</sub>	0.5L	±1.5	-0.1	-0.1	0.0
0.2I <sub>b</sub>	0.5L	±1.0	-0.1	-0.1	-0.1
0.5I <sub>b</sub>	0.5L	±1.0	-0.1	0.0	-0.1
I <sub>b</sub>	0.5L	±1.0	0.0	0.0	-0.1
0.5I <sub>max</sub>	0.5L	±1.0	-0.1	-0.1	-0.1
I <sub>max</sub>	0.5L	±1.0	-0.1	-0.1	0.0
0.1I <sub>b</sub>	0.8C	±1.5	-0.1	-0.1	-0.1
0.2I <sub>b</sub>	0.8C	±1.0	-0.1	0.0	-0.1
0.5I <sub>b</sub>	0.8C	±1.0	-0.1	-0.1	0.0
I <sub>b</sub>	0.8C	±1.0	0.0	-0.1	-0.1
I <sub>max</sub>	0.8C	±1.0	-0.1	-0.1	0.0
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05 $I_b$	1.0	±2.5	-0.1	-0.1	-0.1
0.1 $I_b$	1.0	±2.0	0.0	-0.2	0.0
0.5 $I_b$	1.0	±2.0	-0.2	0.0	-0.1
$I_b$	1.0	±2.0	-0.1	-0.1	0.0
0.5 $I_{max}$	1.0	±2.0	-0.1	-0.1	-0.1
$I_{max}$	1.0	±2.0	-0.1	0.0	-0.1
0.1 $I_b$	0.5L	±2.5	0.0	0.0	0.1
0.2 $I_b$	0.5L	±2.0	0.1	-0.1	0.0
0.5 $I_b$	0.5L	±2.0	-0.1	-0.2	-0.1
$I_b$	0.5L	±2.0	-0.1	-0.1	-0.1
0.5 $I_{max}$	0.5L	±2.0	-0.2	-0.2	-0.1
$I_{max}$	0.5L	±2.0	-0.1	-0.1	0.0
0.2 $I_b$	0.25L	±2.5	-0.1	-0.1	-0.1
0.5 $I_b$	0.25L	±2.5	0.0	0.0	-0.1
$I_b$	0.25L	±2.5	-0.1	-0.1	-0.1
$I_{max}$	0.25L	±2.5	0.0	-0.2	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司  
 Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI202510230A1413

## 2. Test of starting condition

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The meter shall start and continue to register  $0.004I_b$  and  $0.005I_b$ .
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Power factor ( $\cos\Phi$ )	Current	Test Result		
		№25070100003	№25070100004	№25070100005
1.0	$0.004I_b$	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Power factor ( $\sin\Phi$ )	Current	Test Result		
		№25070100003	№25070100004	№25070100005
1.0	$0.005I_b$	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 3. Test of no-load conditions

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The current circuit shall be open circuit and a voltage of 115% of the reference voltage shall be applied to the voltage circuits.
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Power factor:  $\cos\Phi=1.0$  Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Voltage	Test result		
	№25070100003	№25070100004	№25070100005
115% of the reference voltage	Pass	Pass	Pass
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

## 4. Test of meter constant

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: It shall be verified that the relation between the test output and the indication on the display complies with the marking on the name-plate.
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

 Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Power factor (cosΦ)	Test result (imp/kWh)		
	№25070100003	№25070100004	№25070100005
1.0	1000	1000	1000
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Power factor (sinΦ)	Test result (imp/kvarh)		
	№25070100003	№25070100004	№25070100005
1.0	1000	1000	1000
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 5. AC voltage tests

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The test voltage shall be substantially sinusoidal, having a frequency between 45Hz and 65Hz, and applied for 1 min. During this test no flashover, disruptive discharge or puncture shall occur.
3. Test equipment: Tester 860A (4540688)
4. Test result:

Test Voltage r.m.s	Test Result		
	№25070100003	№25070100004	№25070100005
Between circuit and earth:4kV	Pass	Pass	Pass
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 6. Impulse voltage test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The impulse voltage is applied ten times with one polarity and then repeated with the other polarity. The minimum time between the impulses shall be 3s.
3. Test equipment: Tester XTS-11A (03052)
4. Test result:

Impulse Voltage	Test result		
	№25070100003	№25070100004	№25070100005
Impulse waveform 1.2/50µs, 6kV	Pass	Pass	Pass
cosφ=1.0, I <sub>b</sub> , error(%)	-0.1	-0.1	0.0
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 7. Test of ambient temperature influence

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The determination of the mean temperature coefficient for a given temperature shall be made over a temperature range 10K above and 10 K below that temperature, but in no case shall the temperature be outside the specified operating temperature range.
3. Test equipment: High and low temperature test chambers PL-2GT(920218)and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Temperature (K)	Limits of mean temperature coefficient (%/K)	Test result (%/K)		
				№25070100003	№25070100004	№25070100005
0.1I <sub>b</sub>	1.0	-25°C~-5°C	0.05	0.010	-0.005	-0.012
I <sub>b</sub>	1.0		0.05	-0.008	0.009	0.013
I <sub>max</sub>	1.0		0.05	0.006	0.010	-0.003
0.2I <sub>b</sub>	0.5L		0.07	0.008	-0.008	0.010
I <sub>b</sub>	0.5L		0.07	-0.012	-0.010	0.012
I <sub>max</sub>	0.5L		0.07	0.015	0.005	0.003
0.1I <sub>b</sub>	1.0	-5°C~15°C	0.05	0.010	-0.010	-0.006
I <sub>b</sub>	1.0		0.05	0.005	0.011	0.010
I <sub>max</sub>	1.0		0.05	0.012	-0.011	-0.015
0.2I <sub>b</sub>	0.5L		0.07	-0.011	0.005	0.009
I <sub>b</sub>	0.5L		0.07	0.007	0.012	-0.006

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

$I_{max}$	0.5L	15°C~35°C	0.07	-0.006	-0.007	-0.014
$0.1I_b$	1.0		0.05	0.012	0.014	0.012
$I_b$	1.0		0.05	-0.010	0.007	-0.005
$I_{max}$	1.0		0.05	0.007	-0.003	-0.007
$0.2I_b$	0.5L		0.07	0.015	0.010	0.009
$I_b$	0.5L		0.07	0.002	-0.003	-0.008
$I_{max}$	0.5L	35°C~55°C	0.07	0.013	0.009	0.014
$0.1I_b$	1.0		0.05	0.008	-0.012	-0.007
$I_b$	1.0		0.05	-0.010	-0.009	-0.009
$I_{max}$	1.0		0.05	0.005	0.008	-0.012
$0.2I_b$	0.5L		0.07	-0.006	0.010	0.008
$I_b$	0.5L		0.07	0.010	-0.008	-0.003
$I_{max}$	0.5L		0.07	-0.012	-0.010	0.008
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



报告编号: HYI202510230A1413

Current t	Power factor (sinΦ)	Temperature (K)	Limits of mean temperature coefficient (%/K)	Test result (%/K)		
				№25070100003	№25070100004	№25070100005
0.1I <sub>b</sub>	1.0	-25°C~-5°C	0.10	-0.010	-0.010	0.005
I <sub>b</sub>	1.0		0.10	0.007	-0.009	-0.008
I <sub>max</sub>	1.0		0.10	-0.008	0.010	0.011
0.2I <sub>b</sub>	0.5L		0.15	0.007	0.013	-0.010
I <sub>b</sub>	0.5L		0.15	-0.005	0.012	0.007
I <sub>max</sub>	0.5L		0.15	-0.006	0.009	0.015
0.1I <sub>b</sub>	1.0	-5°C~15°C	0.10	0.011	-0.012	-0.004
I <sub>b</sub>	1.0		0.10	0.012	0.008	0.007
I <sub>max</sub>	1.0		0.10	-0.006	0.013	-0.008
0.2I <sub>b</sub>	0.5L		0.15	0.010	0.004	0.004
I <sub>b</sub>	0.5L		0.15	0.007	-0.007	-0.007
I <sub>max</sub>	0.5L		0.15	-0.002	-0.008	-0.005
0.1I <sub>b</sub>	1.0	15°C~35°C	0.10	0.012	-0.006	0.004
I <sub>b</sub>	1.0		0.10	0.006	0.008	-0.008
I <sub>max</sub>	1.0		0.10	0.007	-0.006	0.004
0.2I <sub>b</sub>	0.5L		0.15	-0.009	0.008	-0.008
I <sub>b</sub>	0.5L		0.15	0.011	-0.012	0.010
I <sub>max</sub>	0.5L		0.15	0.008	0.007	0.008
0.1I <sub>b</sub>	1.0	35°C~55°C	0.10	-0.007	0.010	0.013
I <sub>b</sub>	1.0		0.10	0.011	-0.004	0.008
I <sub>max</sub>	1.0		0.10	0.014	-0.009	-0.007
0.2I <sub>b</sub>	0.5L		0.15	0.012	0.011	-0.004
I <sub>b</sub>	0.5L		0.15	0.009	-0.005	0.012
I <sub>max</sub>	0.5L		0.15	-0.013	-0.017	0.015
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

## 8. Test of influence of self-heating

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test Method: After the voltage circuits have been energized at reference voltage for at least 2h for class 1, without any current in the current circuits, the maximum current shall be applied to the current circuits, the meter error shall be measured at unity power factor immediately after the current is applied.
3. Test Equipment: Meter calibration device ST9001D5 (7131019)
4. Test Result:

 Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Limits of variation (%)	Maximum change (%)		
			№25070100003	№25070100004	№25070100005
$I_{max}$	1.0	0.7	0.10	0.08	0.05
$I_{max}$	0.5L	1.0	0.07	0.15	0.15
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Limits of variation (%)	Maximum change (%)		
			№25070100003	№25070100004	№25070100005
$I_{max}$	1.0	1.0	0.06	0.07	0.14
$I_{max}$	0.5L	1.5	0.12	0.11	0.18
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 9. Test of influence of voltage variation

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: Test the variation in percentage errors when voltage variation.
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

 Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Voltage (V)	Limits of variation (%)	Test result (%)		
				№25070100003	№25070100004	№25070100005
$0.05I_b$	1.0	207	0.7	0.02	-0.06	0.04
$I_b$	1.0	207	0.7	-0.08	0.07	-0.10
$I_{max}$	1.0	207	0.7	-0.03	0.08	0.04
$0.1I_b$	0.5L	207	1.0	0.08	-0.02	0.10
$I_b$	0.5L	207	1.0	0.01	-0.04	-0.06
$I_{max}$	0.5L	207	1.0	0.05	0.05	-0.06
$0.05I_b$	1.0	253	0.7	-0.10	0.03	0.01
$I_b$	1.0	253	0.7	0.08	0.05	0.06
$I_{max}$	1.0	253	0.7	0.02	0.07	-0.01

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

0.1I <sub>b</sub>	0.5L	253	1.0	-0.03	0.03	0.10
I <sub>b</sub>	0.5L	253	1.0	0.05	0.05	-0.06
I <sub>max</sub>	0.5L	253	1.0	0.06	0.03	-0.07
0.05I <sub>b</sub>	1.0	184	2.1	0.12	-0.04	-0.07
I <sub>b</sub>	1.0	184	2.1	0.01	-0.05	-0.10
I <sub>max</sub>	1.0	184	2.1	0.08	-0.08	-0.12
0.1I <sub>b</sub>	0.5L	184	3.0	0.16	-0.03	-0.04
I <sub>b</sub>	0.5L	184	3.0	0.02	-0.02	-0.06
I <sub>max</sub>	0.5L	184	3.0	0.15	-0.04	-0.07
0.05I <sub>b</sub>	1.0	264.5	2.1	0.11	0.05	-0.01
I <sub>b</sub>	1.0	264.5	2.1	0.15	0.09	0.13
I <sub>max</sub>	1.0	264.5	2.1	0.04	0.12	-0.08
0.1I <sub>b</sub>	0.5L	264.5	3.0	-0.10	0.15	0.20
I <sub>b</sub>	0.5L	264.5	3.0	0.06	0.09	0.10
I <sub>max</sub>	0.5L	264.5	3.0	0.14	0.15	-0.12
0.05I <sub>b</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>b</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>max</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
0.1I <sub>b</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>b</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>max</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



Current	Power factor (sinΦ)	Voltage (V)	Limits of variation (%)	Test result (%)		
				№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	207	1.0	-0.05	0.11	-0.10
I <sub>b</sub>	1.0	207	1.0	0.05	0.07	0.08
I <sub>max</sub>	1.0	207	1.0	0.08	0.10	-0.01
0.1I <sub>b</sub>	0.5L	207	1.5	-0.01	-0.04	-0.03
I <sub>b</sub>	0.5L	207	1.5	0.00	0.07	0.02
I <sub>max</sub>	0.5L	207	1.5	-0.01	0.05	0.11
0.05I <sub>b</sub>	1.0	253	1.0	0.12	0.03	0.02
I <sub>b</sub>	1.0	253	1.0	0.04	0.01	0.04
I <sub>max</sub>	1.0	253	1.0	0.09	0.14	0.01
0.1I <sub>b</sub>	0.5L	253	1.5	0.08	0.04	0.07
I <sub>b</sub>	0.5L	253	1.5	0.01	0.09	0.01
I <sub>max</sub>	0.5L	253	1.5	0.00	0.06	0.10
0.05I <sub>b</sub>	1.0	184	3.0	-0.03	-0.01	-0.02
I <sub>b</sub>	1.0	184	3.0	-0.09	0.03	-0.12
I <sub>max</sub>	1.0	184	3.0	0.07	0.08	-0.08
0.1I <sub>b</sub>	0.5L	184	4.5	0.12	0.07	0.00
I <sub>b</sub>	0.5L	184	4.5	0.07	0.12	0.12
I <sub>max</sub>	0.5L	184	4.5	0.09	0.15	0.07
0.05I <sub>b</sub>	1.0	264.5	3.0	0.11	0.03	0.01
I <sub>b</sub>	1.0	264.5	3.0	0.06	0.02	0.07
I <sub>max</sub>	1.0	264.5	3.0	0.10	0.07	0.02
0.1I <sub>b</sub>	0.5L	264.5	4.5	0.08	0.07	-0.12
I <sub>b</sub>	0.5L	264.5	4.5	0.17	0.08	0.09
I <sub>max</sub>	0.5L	264.5	4.5	0.18	0.18	0.22
0.05I <sub>b</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>b</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>max</sub>	1.0	< 184	-100 ~ 10	Pass	Pass	Pass
0.1I <sub>b</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>b</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
I <sub>max</sub>	0.5L	< 184	-100 ~ 10	Pass	Pass	Pass
<b>Test conclusion</b>				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



## 10. Test of influence of frequency variation

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: Test the variation in percentage errors when frequency variation at  $\pm 2\%$ .
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Frequency (Hz)	Limits of variation (%)	Test result (%)		
				No25070100003	No25070100004	No25070100005
0.05I <sub>b</sub>	1.0	49	0.5	0.05	-0.06	-0.02
I <sub>b</sub>	1.0	49	0.5	0.07	0.03	-0.05
I <sub>max</sub>	1.0	49	0.5	0.04	0.05	-0.04
0.1I <sub>b</sub>	0.5L	49	0.7	0.08	-0.02	-0.03
I <sub>b</sub>	0.5L	49	0.7	0.02	0.05	0.03
I <sub>max</sub>	0.5L	49	0.7	0.06	0.08	0.02
0.05I <sub>b</sub>	1.0	51	0.5	0.04	0.04	-0.01
I <sub>b</sub>	1.0	51	0.5	-0.03	0.02	-0.01
I <sub>max</sub>	1.0	51	0.5	0.03	0.04	0.07
0.1I <sub>b</sub>	0.5L	51	0.7	0.02	0.04	0.05
I <sub>b</sub>	0.5L	51	0.7	0.07	0.05	-0.02
I <sub>max</sub>	0.5L	51	0.7	0.08	0.10	-0.08
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Frequency (Hz)	Limits of variation (%)	Test result (%)		
				No25070100003	No25070100004	No25070100005
0.05I <sub>b</sub>	1.0	49	2.5	-0.02	0.10	-0.05
I <sub>b</sub>	1.0	49	2.5	0.08	0.07	-0.08
I <sub>max</sub>	1.0	49	2.5	0.13	0.08	-0.12
0.1I <sub>b</sub>	0.5L	49	2.5	0.05	-0.02	0.06
I <sub>b</sub>	0.5L	49	2.5	0.12	-0.12	0.04
I <sub>max</sub>	0.5L	49	2.5	0.09	0.12	0.01
0.05I <sub>b</sub>	1.0	51	2.5	0.02	0.05	0.02
I <sub>b</sub>	1.0	51	2.5	0.08	-0.06	0.01
I <sub>max</sub>	1.0	51	2.5	0.02	0.02	0.02
0.1I <sub>b</sub>	0.5L	51	2.5	-0.02	0.12	-0.03
I <sub>b</sub>	0.5L	51	2.5	0.06	0.08	0.07

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

$I_{max}$	0.5L	51	2.5	0.08	0.10	-0.12
Test conclusion				Pass	Pass	Pass

## 11. Test of magnetic induction of external origin (0.5mT)

- Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
- Test method: A magnetic induction of external origin of 0.5mT produced by a current of the same frequency as that of the voltage applied to the meter and under the most unfavorable conditions of phase and direction shall not cause a variation in the percentage error of the meter exceeding limits of variation.
- Test equipment: Meter calibration device ST9001D5 (7131019) and External magnetic field test bench ZHZ26A(09021)
- Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Direction of magnetic		Limits of variation (%)	Test result (%)		
					№25070100003	№25070100004	№25070100005
$I_b$	1.0	Upright	Same phase	2.0	0.13	-0.02	0.12
			60°	2.0	0.09	0.08	0.09
		Parallel	Same phase	2.0	0.10	0.12	0.05
			60°	2.0	-0.03	0.10	0.12
Test conclusion					Pass	Pass	Pass

Current	Power factor (sinΦ)	Direction of magnetic		Limits of variation (%)	Test result (%)		
					№25070100003	№25070100004	№25070100005
$I_b$	1.0	Upright	Same phase	3.0	0.07	0.14	0.04
			60°	3.0	0.15	0.12	0.11
		Parallel	Same phase	3.0	0.12	0.15	0.07
			60°	3.0	0.03	0.05	0.12
Test conclusion					Pass	Pass	Pass

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

 厦门泓益检测有限公司  
 Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 12. Test of the influence of harmonics

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: Test the variation in percentage errors at power with harmonic.
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Influence quantity	Current	Power factor (cosΦ)	Limits of variation (%)	Test result (%)		
				№2507010000 3	№2507010000 4	№2507010000 5
Harmonic components in the current and voltage circuits	$0.5I_{max}$	1.0	0.8	0.09	0.13	0.11
odd-harmonics in the A.C. Current circuit	$0.5I_b$	1.0	3.0	0.19	0.14	0.15
Sub-harmonics in the A.C. Current circuit	$0.5I_b$	1.0	3.0	0.22	0.27	0.22
DC and even harmonics in the current circuit	$\frac{I_{max}}{\sqrt{2}}$	1.0	3.0	0.30	0.35	0.35
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Influence quantity	Current	Power factor (sinΦ)	Limits of variation (%)	Test result (%)		
				№2507010000 3	№2507010000 4	№2507010000 5
DC and even harmonics in the current circuit	$\frac{I_{max}}{\sqrt{2}}$	1.0	6.0	0.30	0.23	0.20
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



### 13. Test of influence of short time over currents

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: After the application of the short- time over current, the meter shall perform correctly when back to its initial working.
3. Test equipment: Pulse current test bench XTS-12D(03017) and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Limits of variation (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
$I_b$	1.0	1.5	0.11	0.15	0.09
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Limits of variation (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
$I_b$	1.0	1.5	0.12	0.08	0.10
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

### 14. Spring hammer test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The meter shall be mounted in its normal working position and the spring hammer shall act on the outer surfaces of the meter cover (including windows) and on the terminal cover with a kinetic energy of  $0.2J \pm 0.02J$ .
3. Test equipment: Impact test bench TY2(027)
4. Test result:

Test part	Test requirement	Test result		
		№25070100003	№25070100004	№25070100005
Outside surface	No damage	Pass	Pass	Pass
Terminal cover	No damage	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>



## 15. Test of resistance to heat and fire

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The contact with the glow wire may occur at any random location.If the terminal block is integral with the meter base,It is sufficient to carry out the test only on the terminal block.
3. Test equipment: Hot wire test device ZHZ13 (35093)
4. Test result:

Location	Temperature (°C)	Requirement	Test result		
			№25070100003	№25070100004	№25070100005
Terminal block	960	No burn	Pass	Pass	Pass
Terminal Cover	650	No burn	Pass	Pass	Pass
Case	650	No burn	Pass	Pass	Pass
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 16. Test of power consumption

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The power consumption in the voltage and current circuit at reference values of the influence quantities.
3. Test equipment: Low power factor watt-meter D5-W (20149) and DMM 7150(303645)
4. Test result:

Power factor:  $\cos\Phi=1.0$  Reference frequency :50Hz Current :5(60)A Reference voltage:230V

Test item	Specified range of power consumption (active)	Test result (%)		
		№25070100003	№25070100004	№25070100005
Voltage circuit	2 W	0.18W	0.18W	0.19W
	10VA	1.05VA	1.06VA	1.06VA
Current circuit	4VA	0.01VA	0.01VA	0.01VA
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>



## 17. Test of influence of heating

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: With each current circuit of the meter carrying maximum current and with each voltage circuit carrying 1.15 times the reference voltage, the temperature rise of the external surface shall not exceed 25K, with an ambient temperature of 40°C.
3. Test equipment: Digital thermometer WMY-01(212)
4. Test result:  
 Power factor:cosΦ= 1.0 Voltage:264.5V Reference frequency:50Hz Current:5(60)A  
 Temperature :40°C

Test temperature arise part	Limits of temperature rise (K)	Test result (K)		
		№25070100003	№25070100004	№25070100005
Outside surface of cover	25	7	7	6
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 18. Damp heat cyclic test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
2. Test method: After damp heat cyclic test, the meter shall show no damage or change of the information and shall operate correctly.
3. Test equipment: Damp heat cyclic test chambers SETH-101U/P(634003) and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	±1.5	-0.1	0.0	0.0
I <sub>b</sub>	1.0	±1.0	0.0	-0.1	-0.1
I <sub>max</sub>	1.0	±1.0	-0.1	0.0	0.0
0.1I <sub>b</sub>	0.5L	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.5L	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.5L	±1.0	-0.2	-0.1	-0.1
0.1I <sub>b</sub>	0.8C	±1.5	-0.1	-0.2	-0.2
I <sub>b</sub>	0.8C	±1.0	-0.1	-0.1	-0.1
I <sub>max</sub>	0.8C	±1.0	-0.2	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



报告编号: HYI202510230A1413

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05 $I_b$	1.0	±2.5	-0.2	-0.1	-0.1
$I_b$	1.0	±2.0	-0.1	-0.2	-0.2
$I_{max}$	1.0	±2.0	-0.1	-0.1	-0.1
0.1 $I_b$	0.5L	±2.5	-0.2	-0.1	-0.1
$I_b$	0.5L	±2.0	-0.1	-0.2	-0.2
$I_{max}$	0.5L	±2.0	-0.2	0.1	0.0
0.2 $I_b$	0.25L	±2.5	-0.2	-0.1	-0.1
$I_b$	0.25L	±2.5	-0.1	-0.2	-0.2
$I_{max}$	0.25L	±2.5	-0.1	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 19. Vibration test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The meter shall show no damage or change of the information and shall operate correctly in accordance with the requirements of this standard after the test.
3. Test equipment: Vibration test bench D-1000-5(920407)and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	±1.5	-0.1	0.0	0.0
I <sub>b</sub>	1.0	±1.0	-0.2	-0.1	-0.1
I <sub>max</sub>	1.0	±1.0	-0.1	-0.2	-0.2
0.1I <sub>b</sub>	0.5L	±1.5	-0.1	-0.1	-0.1
I <sub>b</sub>	0.5L	±1.0	-0.2	-0.1	-0.1
I <sub>max</sub>	0.5L	±1.0	0.2	0.1	0.2
0.1I <sub>b</sub>	0.8C	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.8C	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.8C	±1.0	-0.1	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05 I <sub>b</sub>	1.0	±2.5	-0.2	-0.1	-0.1
I <sub>b</sub>	1.0	±2.0	-0.1	-0.2	-0.2
I <sub>max</sub>	1.0	±2.0	0.1	0.0	0.1
0.1 I <sub>b</sub>	0.5L	±2.5	-0.2	-0.2	-0.1
I <sub>b</sub>	0.5L	±2.0	-0.2	-0.1	-0.2
I <sub>max</sub>	0.5L	±2.0	-0.2	0.1	0.1
0.2 I <sub>b</sub>	0.25L	±2.5	-0.1	-0.2	-0.1
I <sub>b</sub>	0.25L	±2.5	-0.2	-0.1	-0.2
I <sub>max</sub>	0.25L	±2.5	-0.1	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司  
 Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 20. Shock test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: The meter shall show no damage or change of the information and shall operate correctly in accordance with the requirements of this standard after the test.
3. Test equipment: Shock test bench CP-100(120807)and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	1.0	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	1.0	±1.0	-0.1	-0.1	-0.1
0.1I <sub>b</sub>	0.5L	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.5L	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.5L	±1.0	-0.1	-0.1	-0.1
0.1I <sub>b</sub>	0.8C	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.8C	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.8C	±1.0	-0.1	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05 I <sub>b</sub>	1.0	±2.5	0.0	0.1	0.0
I <sub>b</sub>	1.0	±2.0	-0.2	-0.1	-0.1
I <sub>max</sub>	1.0	±2.0	-0.1	-0.2	-0.2
0.1 I <sub>b</sub>	0.5L	±2.5	-0.1	-0.1	-0.1
I <sub>b</sub>	0.5L	±2.0	0.1	0.1	0.0
I <sub>max</sub>	0.5L	±2.0	-0.2	-0.1	-0.1
0.2 I <sub>b</sub>	0.25L	±2.5	-0.1	-0.2	-0.2
I <sub>b</sub>	0.25L	±2.5	-0.2	-0.1	-0.1
I <sub>max</sub>	0.25L	±2.5	-0.1	-0.2	-0.2
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



## 21. Dry heat test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: After dry heat test, the meter shall show no damage or change of the information and shall operate correctly .
3. Test equipment: High and low temperature test chambers PL-2G(920218)and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			No25070100003	No25070100004	No25070100005
0.05I <sub>b</sub>	1.0	±1.5	-0.1	-0.2	-0.2
I <sub>b</sub>	1.0	±1.0	-0.1	-0.1	-0.1
I <sub>max</sub>	1.0	±1.0	-0.2	-0.1	-0.1
0.1I <sub>b</sub>	0.5L	±1.5	-0.1	-0.2	-0.2
I <sub>b</sub>	0.5L	±1.0	-0.1	-0.1	-0.1
I <sub>max</sub>	0.5L	±1.0	-0.2	-0.1	-0.1
0.1I <sub>b</sub>	0.8C	±1.5	-0.1	-0.2	-0.2
I <sub>b</sub>	0.8C	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.8C	±1.0	-0.2	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			No25070100003	No25070100004	No25070100005
0.05 I <sub>b</sub>	1.0	±2.5	0.0	0.1	0.2
I <sub>b</sub>	1.0	±2.0	-0.1	-0.2	-0.2
I <sub>max</sub>	1.0	±2.0	-0.1	-0.1	-0.1
0.1 I <sub>b</sub>	0.5L	±2.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.5L	±2.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.5L	±2.0	-0.1	0.1	0.0
0.2 I <sub>b</sub>	0.25L	±2.5	-0.1	-0.1	0.0
I <sub>b</sub>	0.25L	±2.5	-0.1	0.2	0.1
I <sub>max</sub>	0.25L	±2.5	-0.2	0.2	0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司  
 Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



## 22. Cold test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: After cold test, the meter shall show no damage or change of the information and shall operate correctly.
3. Test equipment: High and low temperature test chambers PL-2G(920218)and Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Current	Power factor (cosΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05I <sub>b</sub>	1.0	±1.5	0.0	0.0	0.0
I <sub>b</sub>	1.0	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	1.0	±1.0	-0.1	-0.1	-0.1
0.1I <sub>b</sub>	0.5L	±1.5	-0.2	-0.1	-0.1
I <sub>b</sub>	0.5L	±1.0	-0.1	-0.2	-0.2
I <sub>max</sub>	0.5L	±1.0	-0.1	-0.1	-0.1
0.1I <sub>b</sub>	0.8C	±1.5	-0.1	-0.2	-0.2
I <sub>b</sub>	0.8C	±1.0	-0.1	-0.1	-0.1
I <sub>max</sub>	0.8C	±1.0	-0.1	-0.2	-0.2
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Power factor (sinΦ)	Percentage error limits (%)	Test result (%)		
			№25070100003	№25070100004	№25070100005
0.05 I <sub>b</sub>	1.0	±2.5	0.0	0.0	0.0
I <sub>b</sub>	1.0	±2.0	-0.1	-0.2	-0.2
I <sub>max</sub>	1.0	±2.0	-0.1	-0.1	-0.1
0.1 I <sub>b</sub>	0.5L	±2.5	-0.2	-0.1	-0.2
I <sub>b</sub>	0.5L	±2.0	0.2	-0.1	-0.1
I <sub>max</sub>	0.5L	±2.0	0.2	-0.2	-0.1
0.2 I <sub>b</sub>	0.25L	±2.5	0.2	0.1	0.1
I <sub>b</sub>	0.25L	±2.5	0.2	-0.1	-0.2
I <sub>max</sub>	0.25L	±2.5	0.1	-0.1	-0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



### 23. Test of immunity to electromagnetic HF fields

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: 1) Without any current in the current circuits, test the change in the register.  
With basic current  $I_b$  and power factor equal to 1.  
2) At sensitive frequencies or frequencies of dominant interest, test the variation of error.
3. Test equipment: Signal generator PMM3030-02(000WJ81009) and Power amplifier AS0104-200/200 (1034148) and Power amplifier A P32MT255 (S/N:0906-943)

#### 4. Test result:

Power factor:  $\cos\Phi=1.0$  Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Test field strength	Frequency (MHz)	Limits of variation (%)	Test result		
			No25070100003	No25070100004	No25070100005
10V/m	80	2.0	0.0	0.0	0.1
	100		0.2	0.1	0.0
	120		0.1	0.1	0.2
	200		0.1	0.2	0.2
	300		0.2	0.2	0.1
	400		0.1	0.1	0.1
	500		0.1	0.1	0.0
	600		0.1	0.2	0.1
	700		0.0	0.2	0.2
	800		0.1	0.1	0.1
	900		0.1	0.1	0.2
	1000		0.2	0.1	0.1
	1100		0.0	0.2	0.1
	1200		0.1	0.1	0.1
	1300		0.1	0.1	0.0
	1400		0.1	0.1	0.0
	1500		0.1	0.2	0.0
	1000		0.0	0.2	0.1
	1700		0.0	0.1	0.1
	1800		0.1	0.1	0.1
1900	0.1	0.0	0.0		
2000	0.0	0.1	0.1		
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.


 Reference frequency : 50Hz Reference voltage: 230V

Frequency band and field strength	Limits of charge in the register	Test result		
		№25070100003	№25070100004	№25070100005
80~2000MHz 30V/m	≤0.0184kWh	Pass	Pass	Pass
	No output	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 24. Fast transient burst test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Burst generator EFT-406N (EFT0460905)
4. Test result:

 Reference frequency: 50Hz Reference voltage : 230V

Test voltage	Test content	Test result		
		№25070100003	№25070100004	№25070100005
4kV	Pulse Output	Pass	Pass	Pass
Register function	≤0.184kWh	Pass	Pass	Pass
$I_b$ Error (%)	≤4.0%	0.2	0.1	0.2
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 25. Test of immunity to electrostatic discharges

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Electrostatic discharge generator ESD-203A(ESD-203A0130102)
4. Test result:

 Reference frequency : 50Hz Reference voltage : 230V

Test voltage	Limit value allowable %	Test result		
		№25070100003	№25070100004	№25070100005
contact discharge 8kV,	≤0.0184kWh	Pass	Pass	Pass
air discharge 15kV	No output	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 26. Tests of the effect of voltage dips and short interruptions

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Cycle drop device VDS-1132A(VDS-1132A0130101)and Meter calibration device ST9001D5 (7131019)
4. Test result:

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.


 Reference frequency : 50Hz Reference voltage : 230V

Interrupt voltage and time	Test content	Limits of charge in the register	Test result		
			№25070100003	№25070100004	№25070100005
$\Delta U=100\%$ 1s/50ms	Register Function	$\leq 0.0184kWh$	Pass	Pass	Pass
	Output pulse	No output	Pass	Pass	Pass
$\Delta U=100\%$ 20ms	Register Function	$\leq 0.0184kWh$	Pass	Pass	Pass
	Output pulse	No output	Pass	Pass	Pass
$\Delta U=50\%$ 1min	Register Function	$\leq 0.0184kWh$	Pass	Pass	Pass
	Output pulse	No output	Pass	Pass	Pass
$I_b$	Error (%)		-0.1	0.0	0.0
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 27. Test of continuous magnetic induction of external origin

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: Put 1000At magnetic field to touchable part of the meter surface.
3. Test equipment: DC steady current source YJ-10A(6102) and Meter calibration device ST9001D5 (7131019).
4. Test result:

 Reference frequency : 50Hz Current : 5(60)A Reference voltage: 230V

Current	Location	Power factor (cos $\Phi$ )	Limits of variation (%)	Test result (%)		
				№25070100003	№25070100004	№25070100005
$I_b$	Front	1.0	2.0	0.10	0.05	-0.02
$I_b$	Up	1.0	2.0	0.10	0.10	0.03
$I_b$	Left	1.0	2.0	0.05	0.03	0.04
$I_b$	Right	1.0	2.0	0.13	-0.05	0.14
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Current	Location	Power factor (sin $\Phi$ )	Limits of variation (%)	Test result (%)		
				№25070100003	№25070100004	№25070100005
$I_b$	Front	1.0	3.0	0.08	0.12	0.07
$I_b$	Up	1.0	3.0	0.15	-0.07	-0.02
$I_b$	Left	1.0	3.0	0.13	0.09	0.08
$I_b$	Right	1.0	3.0	0.05	0.12	0.17
Test conclusion				<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



## 28. Marking and elements test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: Checked by inspection
3. Test equipment: Checked by inspection
4. Test result:

Test item	Test result		
	№25070100003	№25070100004	№25070100005
Case	Pass	Pass	Pass
Name-plates and marking	Pass	Pass	Pass
Terminal and Line connecting diagram	Pass	Pass	Pass
Clearance and creep age distances	Pass	Pass	Pass
Seal	Pass	Pass	Pass
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 29. Test of supply voltage operating range

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Supply voltage operating range	Test result		
	№25070100003	№25070100004	№25070100005
Operating range(0.9~1.1) $U_n$	Pass	Pass	Pass
Limit operating range(0~1.15) $U_n$	Pass	Pass	Pass
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

## 30. Test of initial start-up

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
3. Test equipment: Meter calibration device ST9001D5 (7131019)
4. Test result:

Reference frequency :50Hz Current :5(60)A Reference voltage: 230V

Test item	Test result		
	№25070100003	№25070100004	№25070100005
Initial start-up	Pass	Pass	Pass
Test conclusion	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



### 31. Surge immunity test

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11: 2003
2. Test method: After application of the surge immunity, test the change in the register.
3. Test equipment: Surge generator LSG-510A (LSG05100905)
4. Test result:

 Reference frequency: 50Hz Reference voltage: 230V

Test content	Limits of charge in the register	Test result		
		№25070100003	№25070100004	№25070100005
Test voltage: 8kV Register function	≤0.023kWh	Pass	Pass	Pass
Pulse output	No output	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

### 32. Radio interference measurement

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Electromagnetic disturbance test receiver PMM9010 (696WX21006) and Three-phase power supply network of artificial L3-32 (0120X90108).
4. Test result:

#### a. Limit value of conducted disturbances:

 Reference voltage :230V Power factor: cosΦ=1.0 Reference frequency :50Hz Current :0.5A

Frequency (MHz)	Limits dB(μV)		Test result №25070100003
	Peak value	Average value	
0.15 ~ 0.50	66 ~ 56	56 ~ 46	≤33
0.50 ~ 5	56	46	≤30
5 ~ 30	60	50	≤27
Test conclusion			<b>Pass</b>

#### b . Limit value of radiation disturbances:

 Reference voltage: 230V Power factor: cosΦ=1.0 Reference frequency :50Hz Current :0.5A

Frequency (MHz)	Peak value dB(μV/m)	Test result
		№25070100003
30 ~ 230	40	≤28
230 ~ 1000	47	≤32
Test conclusion		<b>Pass</b>



### 33. Test of immunity to conducted disturbances, induced radio-frequency fields

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: NSG4070-75 Conducted disturbances test system (35761)
4. Test result:

Reference voltage :230V Power factor: cosΦ=1.0 Reference frequency :50Hz Current: 5(60)A

Test voltage	Frequency (MHz)	Limits of variation (%)	Test result		
			№25070100003	№25070100004	№25070100005
10V	0.15	2.0	0.1	0.1	0.0
	0.5		0.2	0.1	0.1
	1.0		0.1	0.1	0.2
	2.0		0.2	0.2	0.1
	5.0		0.1	0.3	0.2
	10.0		0.2	0.1	0.1
	20.0		0.2	0.1	0.2
	30.0		0.0	0.2	0.2
	50.0		0.1	0.1	0.2
	80.0		0.0	0.0	0.1
Test conclusion			<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

Reference voltage :230V Reference frequency:50Hz

Test content	Limits of charge in the register	Test result		
		№25070100003	№25070100004	№25070100005
Frequency range: 150kHz ~ 80MHz	≤0.0184kWh	Pass	Pass	Pass
	No output	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



### 34. Test of solar radiation

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Xenon climate test chamber TET080D (030117)
4. Test result:

Test condition	Requirement	Test result		
		№25070100003	№25070100004	№25070100005
8h irradiation and 16h darkness 3cycles Temperature:55°C	The appearance and, in particular, the legibility of markings shall not be altered. The function of meter shall not be impaired.	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

### 35. Test of protection against penetration of water

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Swing pipe rain test device BGL-06/08 (040196)
4. Test result:

Test condition	Requirement	Test result		
		№25070100003	№25070100004	№25070100005
IPX4	Any ingress of water shall be only in a quality not impairing the operation the meter, and its dielectric strength (insulating strength)	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.



### 36. Test of protection against penetration of dust

1. Requirement: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
2. Test method: IEC62053-21:2003 IEC62053-23:2003 IEC62052-11:2003
3. Test equipment: Dust test chamber FCH-20 (990122)
4. Test result:

Test condition	Requirement	Test result		
		No25070100003	No25070100004	No25070100005
IP5X	Any ingress of dust shall be only in a quantity not impairing the operation of the meter and its dielectric strength (insulating strength)	Pass	Pass	Pass
Test conclusion		<b>Pass</b>	<b>Pass</b>	<b>Pass</b>



报告编号: HYI202510230A1413

Meter Photos:



**--END OF REPORT--**

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of Hongyi Testing, this test report shall not be copied except in full and published as advertisement Hongyi Physical & Chemical Lab.

厦门泓益检测有限公司

Xiamen Hongyi Testing Co., Ltd.

地址: 福建省厦门市同安区轻工食品工业区美禾路 99 号

ADDRESS: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District, Xiamen City, Fujian Province,

邮箱: hongyotest@123.com



Attention:

1. The report is invalid without the 'Inspection Report Seal' or the official seal of the inspection unit.
2. Without the written consent of this laboratory, partial copying of this report is not allowed.
3. The report is invalid without the signatures of the chief inspector, reviewer, and approver.
4. The report is invalid if altered.
5. If there are any objections to the test report, they should be raised with the testing unit within fifteen days from the date of receipt of the report; late submissions will not be accepted.
6. The commissioned testing is only responsible for the samples provided.

Add: No. 99 Meihe Road, Light Industry Food Industrial Zone, Tongan District,  
Xiamen City, Fujian Province,